

# ACLAD Operations Status

8/9/22

# ACLAD STATUS

- **CURRENTLY PUMPING 52,000 GALLONS PER DAY**
- **Modified Pump #4 (lower Figtree) drain pipe**
  - Currently pumping 14,000 GPD
- **Replaced pump in Well #16 (Petak/Sweetbay)**
- **Installed power pole in well #6 (Clovetree)**
- **Removed wood chip from output meter**
  - We have to shut the system down to service the output meter
  - There appears to be more debris in the system
  - Installing 2 bypass valves to allow for servicing without system shut down
- **ACLAD Near-term Plan**
  - **Replace pump in Well #2 (lower Narcissa)**
  - **Trouble shoot Well # 15 ( Narcissa and Vanderlip)**

# ACLAD Summary Report Aug 9, 2022

